



## Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
NL-2288 EA Rijswijk  
Postbus 70  
NL-2280 AB Rijswijk  
Tel.: +31 (0)88 998 44 00  
Fax: +31 (0)88 998 44 20  
E-mail: [info@kiwa.nl](mailto:info@kiwa.nl)

Optional:



Member of  
[www.eota.eu](http://www.eota.eu)

# European Technical Assessment

# ETA-24/0499 of 02-07-2024

## General Part

### Technical Assessment Body issuing the European Technical Assessment:

Kiwa Nederland B.V., Sir Winston Churchillaan 273, 2288 EA Rijswijk, [www.kiwa.nl](http://www.kiwa.nl)

### Trade name of the construction product

**WIDOSEAL-LF 1K**

### Product family to which the construction product belongs

Liquid applied roof waterproofing kit based on 1K SMP

### Manufacturer

Widopan Produkte GmbH  
Ostereichen 3  
21714 Hammah  
Germany

### Manufacturing plant(s)

Widopan Produkte GmbH  
Ostereichen 3  
21714 Hammah  
Germany

### This European Technical Assessment contains

6 pages including 2 Annexes which form an integral part of this assessment.

### This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

“EAD 030350-00-0402 “Liquid applied roof waterproofing kits”, version August 2018.

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## Specific parts

### 1. Technical description of the product

The liquid applied roof waterproofing kit WIDOSEAL-LF 1K is a kit, which consists of the components:

- fleece "Polyestervlies G120", Polyester fleece with a grammage of 120 g/m<sup>2</sup>,
- water proofing membrane "WIDOSEAL-LF 1K" based on 1K SMP

For an adequate adhesion of the waterproofing layer – depending on the type of substrate – a primer is required. In general, the primer belonging to the substrate is given in the manufacturer technical documents. In single cases the manufacturer is responsible to give guidance which pre-treatment / primer is required.

The minimum applied layer thickness of the roof waterproofing membrane 2.2 mm.

As an assembled system these components form a homogeneous seamless roof waterproofing kit.

The components and the system build-up of the roof waterproofing kit "WIDOSEAL-LF 1K" is given in Annex A.

### 2. Specification of the intended use(s) in accordance with the applicable European Assessment Document (hereinafter EAD)

The product is used for the waterproofing of roof surfaces against penetration of atmospheric water.

In the technical file the manufacturer gives information concerning the substrates which the product is suitable for and how these substrates shall be pre-treated. It comprises all necessary information for the production and the installation and repair of the kit and is deposited at Kiwa.

The levels of use categories are given in Annex A.

The verification and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the product of at least 25 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

The levels of use categories and performances given in Section 3 are only valid if the liquid applied roof waterproofing is used in compliance with the specification and conditions given in Annex B and the installation of the manufacture stated in the technical file.

**3. Performance of the product and references to the methods used for its assessment**

**3.1 Mechanical resistance and stability (BWR 1)**

Not applicable

**3.2 Safety in case of fire (BWR 2)**

<b>Essential characteristic</b>	<b>Performance</b>
External fire performance	See Annex A
Reaction to fire	See Annex A

**3.3 Hygiene, health and the environment (BWR 3)**

<b>Essential characteristic</b>	<b>Performance</b>
Content, emission and/or release of dangerous substances	No performance assessed
Resistance to water vapour	See Annex A
Watertightness	See Annex A
Resistance to wind loads	See Annex A
Resistance to mechanical damage (perforation)	See Annex A
Resistance to fatigue movement	See Annex A
Resistance to the effects of low and high surface temperature	See Annex A
Resistance to ageing media (heat and water)	See Annex A
Resistance to UV radiation in the presence of moisture	See Annex A
Resistance to plant roots	See Annex A
Effects of variations in kit components and site practices	No performance assessed
Effect of day joints	See Annex A

**3.4 Safety and accessibility in use (BWR 4)**

<b>Essential characteristic</b>	<b>Performance</b>
Slipperiness	See Annex A

**3.5 Protection against noise (BWR 5)**

Not applicable

**3.6 Energy economy and heat retention (BWR 6)**

Not applicable

**3.7 Sustainable use of natural resources (BWR 7)**

For the sustainable use of natural resources no performance was investigated for this product

**3.8 General aspects**

The verification of durability and serviceability is part of testing the essential characteristics. Durability and serviceability are only ensured if the specifications of intended use according to Annex B and the specification of the technical file of the manufacturer are kept.

**4. Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base**

According to Decision of the Commission of 12 October 1998 (98/599/EC) (OJ L 287 of 24.10.98, p.30) as amended by Decision of the Commission of 8 January 2001 (2001/596/EC) (OJ L 209 of 02.08.2001, p33), the system of assessment and verification of constancy of performance (see Annex V and Article 65 Paragraph 2 to Regulation (EU) No 305/2011) given in the following table applies.

Product	Intended uses(s)	Level or class	System
Liquid applied roof waterproofing kits	For uses subject to external fire performance regulations	E	3
	For uses subject to reaction to fire	B <sub>ROOF</sub> (t1)	
	All other roof waterproofing uses all other characteristics	-	

**5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**

Technical details necessary for the implementation of the AVCP system are laid down on the control plan deposited at Kiwa.


Issued in Rijswijk on 02-07-2024 by



Ron Scheepers

Kiwa Nederland B.V.

## Annex A



- 1: Substrate concrete
- 2: Membrane: WIDOSEAL-LF 1K
- 3: Fleece: Polyestervlies G120/Polyestervlies G165

Classification of the roof waterproofing system “WIDOSEAL-LF 1K”

	<b>WIDOSEAL-LF 1K</b>
Minimum consumption	2.8 kg/m <sup>2</sup>
Minimum layer thickness	2.2 mm
<u>Classification to use categories according to EAD 030350-00-0402:</u>	
Working life	W3 (25 years)
Climatic zones	M and S (moderate and severe climate)
Resistance to mechanical damage (perforation)	Non-compressible substrates: P4 (from low to special) Compressible substrates (insulation with bituminous sheet): P1-P3, low to normal Compressible substrates (insulation): P1-P2, low to moderate
Roof slope	S1 to S4 (10-30 %)
Lowest surface temperature	TL4 (-30 °C)
Highest surface temperature	TH4 (90 °C)
Use category regarding BWR 3	S/W 2
<u>Performances of the product:</u>	
Reaction to fire: EN 13501-1	E
External fire performance EN 13501-5	B <sub>ROOF</sub> (t1)
Water vapour diffusion resistance factor	μ = 832
Water tightness	passed
Resistance to fatigue movement	W3
Resistance to ageing media (heat and water)	W3
Resistance to plant roots	No performance assessed
Release of dangerous substances	See chapter 3.3
Root resistance	No performance assessed
Resistance to wind loads	≥ 50 kPa for tear-resistant substrates
Slipperiness	No performance assessed

The classification is valid for the following supporting decks:

- all roof pitches < 20°
- any non-combustible continuous decks with a minimum of 10 mm

## **Annex B**

### **Installation**

The levels of use categories and the performance of the roof waterproofing can be assumed only, if the installation is carried out according to the installation instructions stated in the technical file of the manufacturer, in particular taking account of the following points:

- installation by appropriately trained personnel,
- installation of only those components which are marked components of the kit,
- installation with required tools and adjuvants,
- precautions during installation,
- inspecting the roof surface for cleanliness and correct preparation,
- inspecting compliance with suitable weather and curing conditions,
- ensuring a thickness of the waterproofing of at least 2.2 mm by processing of appropriate minimum quantities of material,
- inspections during installation and of the finished product and documentation of the results